

<b>UT Health Science Center:</b> <b>GS5115 - Emergency Eyewash and Safety Showers</b>	
Version 1	Publication Date: 06/14/2022



**Eyewash Weekly Inspection Form**

An emergency eyewash fixture is provided to flush tepid water to the eye, diluting any hazardous materials that may have come into contact with the eyes.

**General Requirements:**

Initial and date in the corresponding box verifying the eyewash station is checked weekly for the following:

- The pathway to the eyewash station is clear of obstructions
- The eyewash fixture is free of obstructions in all directions
- The nozzle dust caps/covers are in place and operating properly
- To test the eyewash station, flush water until clear water flows continually through eyewash head without any leaks, rust, dirt, etc. for approximately 5 seconds. ( If problems are evident, call Physical Plant at 8-5661)

Call Safety Affairs (at 8-6114) with any questions

Year _____	Week 1	Week 2	Week 3	Week 4	Week 5	Comments:
JANUARY						
FEBRUARY						
MARCH						
APRIL						
MAY						
JUNE						
JULY						
AUGUST						
SEPTEMBER						
OCTOBER						
NOVEMBER						
DECEMBER						

Principal Investigator: \_\_\_\_\_

Room #: \_\_\_\_\_